DESCRIPTION OF WORK (Be specific when plans are not submitted)
ERECT A NEW ADDITION TO AN EXISTING PLANT FACILITY AND INSTALL RELATED PARKING AND SITE FACILITIES, PER PLANS.
ADDITION TO BE USED TO MANUFACTURE MACHINE PARTS.

485

REFER: FD HD PD

Sediment Control: 224

BALTIMORE CITY SEDIMENT CONTROL AGREEMENT

STABILIZED CONSTRUCTION ENTRANCE

Title 8 Chapter 11 Sediment Sedimentation Control Regulations

8. All borrow and/or spoil materials shall only be stockpiled within the limits of the permitted site.

9. The proposed gradings will not [illegible]

CITY OF BALTIMORE
DEPARTMENT OF PUBLIC WORKS
BUREAU OF ENGINEERING - WASTE WATER DIVISION

Date of Processing Application 20 Feb 80

Form #145 Hwys. Rev.

NOTICE TO APPLICANT JUN 20 1980

PERMITS REQUIRED BY THE BUREAU OF CONSUMER SERVICES

Permits of the Bureau of Consumer Services are required for the following purposes: Paving, repaving or repairing footways; paving, repaving or surfacing streets removing curb; excavating or backfilling in public streets; planting, pruning or removing trees; erection of sheds, fences, barricades, scaffolds or other structures within the limits of any public street; the opening of any street or roadway for the installation of subsurface structures; storage of materials, and any other work not removed by the above which would require working within the street limits.

In the event any of the above operations necessitate the temporary closing or blocking off of any public streets or alleys, a supplementary permit must be obtained twenty-four (24) hours in advance for this purpose.

The following requirements and regulations are applicable to permits issued for any of the above purposes: fire hydrants, sewer inlets and water or electrical services must be unobstructed; [illegible] street or footway pavers must be adequately protected during construction operations; adequate barricades and warning lights must be employed at all times; sufficient lamping or other illuminating devices will be employed during all hours of darkness. All reasonable precautionary measures shall be employed to safeguard the general public and reduce inconveniences to vehicular traffic to a minimum.

When excavation is granted to store building materials on a street, said materials shall not be piled to a height in excess of eight (8) feet and shall utilize no greater width than one-third (1/3) of the width of the street.

All overhead structures constructed in the footway area shall provide a four (4) foot covered walkway for pedestrians. Every shall be located at least one (1) foot in from the curb line and must be approved by the Bureau of Consumer Services for this purpose, a plat showing the proposed structure must first be presented to, and approved by, the Department of Housing and Community Development.

Excavation may work is undertaken under authority of a permit issued by the Bureau of Consumer Services for the excavation of any street, the [illegible] shall be [illegible] and [illegible] to existing conditions as soon as practicable after the [illegible] through the earth.

Manholes, catchbasins, and [illegible] all concrete work must receive authority of permits issued by this office, must be in accordance with the specifications of the Bureau of Engineering.

Permits fee [illegible] and all of the above enumerated purposes may be obtained from the Application and Permits Division, Bureau of Consumer Services, Room #10 Municipal Office Building (PL. 2-3000 Ext. 241). Cost of permits are dependent upon the purpose for which issued. All permits must be displayed on the site of the operation. The discontinuance or violation of any of the terms of a permit, or the improper use thereof, will be deemed sufficient cause for its cancellation.

EROSION AND SEDIMENT CONTROL
APPROVED
H. Singh Pacheja
SEDIMENT CONTROL REPRESENTATIVE
7.1.80
DATE

BUILDINGS INSPECTION
NO PERMIT SHALL BE ISSUED UNTIL APPROVED BY ALL DEPTS. AND BUREAUS CHECKED BELOW.

DEPT. OR BUR.	REC. BY	DATE	APPR. BY	DATE
PROP. LOC.				
RECORD SECT.				
HIGHWAY ENG				
GRADE & STUDY	CEC	6/16/80	CEC	6/16/80
HIGHWAY DESIGN	SHM	6/16/80	SHM	6/16/80
EROS. CONT'L	SH	7-1-80	SH	7-1-80
WASTE WATER	WRD	6/16/80	WRD	6/13/80
FOOTWAYS	JH	6-21-80	JH	6-20-80
TRAN. & TRAFFIC				
RECEIPTS				
HEALTH DEPT.				
PLANNING				
ZONING	OK	ON	APPLIC.	

REMARKS:

GENERAL NOTES

1. ALL EXISTING INFORMATION TAKEN FROM A SURVEY BY JAMES SPAMER ENGINEERS & SURVEYORS, 8017 YORK RD., TOWSON, MD DATED JAN. 18, 1980
2. ELEVATIONS ARE REFERRED TO MEAN OLD TIDE DATUM OF BALTIMORE CITY (1948) AVERAGE EL. 90.52
3. ON SITE BENCH MARKS SHALL BE AS INDICATED ON BM NO. 1 - CROSS CUT ON SE OF CURB EL. 85.61 ; BM NO. 2 - CROSS CUT ON TOP OF CURB EL 66.97 .
4. ALL GRADING & GRUBBING REQUIRED FOR THIS IMPROVEMENT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR.
5. CONTRACTOR SHALL SOD ALL AREAS UNLESS OTHERWISE INDICATED
6. CONTRACTOR SHALL PAINT PARKING SPACES AS SHOWN WITH ONE COAT OF YELLOW RUBBER BASE TRAFFIC PAINT (PAINT EASTON SPAC
7. CONTRACTOR SHALL VERIFY LOCATION OF ALL EXISTING UTILITIES IN THE FIELD
8. TEST BORING LOCATIONS ARE TAKEN FROM A REPORT DATED MARCH 11, 1971 BY ROBERT E. BALTER, SOIL AND FOUNDATION CONSULTANTS, INC.
9. CONTRACTOR SHALL REFER TO MECHANICAL / ELECTRICAL DWGS. FOR SITE UTILITIES.
10. CONTRACTOR SHALL REPAIR & RESURFACE EXISTING DISTURBED PAVED AREA AND CONC. SIDE WALK DUE TO UNDERGROUND UTILITIES.
11. ALL NEW PAVED AREAS SHALL DRAIN PROPERLY TO INTERNAL CATCH BASINS.
12. PROVIDE CONC PARKING BUMPER AS DETAILED ON THIS DWG. SEE SITE PLAN FOR LOCATION
13. FOR HEIGHT OF RETAINING WALL SEE SITE PLAN

TOTAL NO OF PARKING SPACES : 56
TYPICAL SPACE 9' WIDE x 20' LONG

PLANNING AND ZONING

1) 26th WARD, SECTION 17, BLOCK 6345-D
2) AREA OF PROPERTY 2.5595 A.C.
3) PROPOSED USE: OFFICE AND MANUFACTURING/WAREHOUSE
4) TOTAL OFFICE AREA EXISTING: = 4960 ☐'
TOTAL WAREHOUSE AREA EXISTING = 30168 ☐'
PROPOSED WAREHOUSE 20'x100' = 21200 ☐'

BUREAU OF CONSUMER SERVICES PERMITS REQUIRED SEE ATTACHED RIDER OR LOCATION PLAN.

PRIME PAVE, RESURF. AND/OR REPAIR CEM. CON. FOOTWAYS

RECEIVED
DEPT. OF HOUSING AND COMMUNITY DEVELOPMENT
JUN 3 - 1980
No. 485

LEGEND

EXISTING CONTOURS
PROPOSED CONTOURS
NEW CONC. PAVING
NEW BIT. CONC. PAVING
TEST BORING LOCATION ⊕ B-1
STREET LIGHTS EXISTING ○-6
UTILITY POLE Ø

K-KANE

STREET

Public Alley 16' wide

Retaining ground

Sodding

10" W

Construction Specifics

N 35°04'40" E 480.09'

#111

FUTURE 7'-0" HIGH CHAIN LINK FENCE (TYP.)

AIRCO TECHNICAL INSTITUTE

EXISTING OFFICE & PLANT FACILITY

FLOOR ELEV. 74.0'

EX. TRENCH DRAIN

REPAIR AND RESURFACE EXISTING DISTURBED PAVE AREA

EXISTS. PARKING

PAVED AREA

SEDIMENT TRAP SIZED ON BASIS OF 1800 CUFT SURFACE OF AREA

REMOVE EXISTG CURB (TYP.)

NEW ADDITION 74.00 ± elev.

INLET #21
INLET #22
INLET #23

EXISTING PAVED AREA

S 51°40'09" W 303.55'

RAILROAD

CANTON

WYETH LABORATORIES

LOADING DOCK

EX. C.B.

RAIL SIDING

GRADE 80.00
TOP OF WALL 80.5
GRADE 79.50
½" EXP. JOINT (TYP.)
TOP OF WALL 79.83

WALL ELEVATION

CONCRETE RETAINING WALL
SCALE: 3/16" = 1'-0"

ASPHALT PAVING
2' CLEAR
#3@18
#4@9"
9"
#4@9" #3@18"
GRAVEL BED
4" PIPE @ 10'-0" C
½" EXP. JT. CONT. ASPHALT PAVING

CONCRETE RETAINING WALL
SCALE: 3/16" = 1'-0"

6'-6" BUMPER
APPROX. 9'-6" O.C. MIN. 2 PINS PER BUMPER
1½" Ø PIPE SLEEVE CAST INTO BUMPERS
3'-0" AT CURB
4'-0" @ BLDG.
6" CURB
ASPHALT PAVING
CONC. ASPHALT PAVING
12" Ø PIPE DRIVEN INTO GROUND

CONCRETE BUMPER

4" WIDE C.O.D. SAW CUT, PAINT YELLOW BOTH SIDES OF STEPS

8'-0"
1'-7" CONC CURB BEYOND
4" PIPE SLEEVE
BLACK TOP
71.50
GALV. HORZ. WALL REINF. @ 16" C
4"
8"
2'-8" CONT.
#4 @ 18" O.C.
#3 TEMP @ 8'-0" O.C.
HANDRAIL BAR TYP.
6" CONC. SIDE WALLS
2'-0"
R @ 7.65 - 7'-0"

CONC. STAIR DETAIL
SCALE: 3/4" = 1'-0"

SITE PLAN
SCALE: 1" = 40'-0"

NORTH

1	INSTALL SEDIMENT CONTROL (PERIMETER DIKE)	UNIT	8
2	CLEAR & ROUGH GRADE SITE (APPROX. 2.5 AC.)	UNIT	1
3	START BUILDING CONSTRUCTION	LT	1
4	INSTALL EQUIPMENT	LT	1
5	FINE GRADE & BASE PAVE	SY	1
6	PERMANENT STABILIZE	SY	1
7	FINISH BUILDING CONSTRUCTION	JUN	19
8	REMOVE SEDIMENT CONTROL AFTER RECEIVING PERMISSION TO DO SO FROM SEDIMENT CONTROL	JUN	19
9	CLEAN SWAMPS AND RESTORE AREA OF BASIN, & ALL OTHER DEVICES	JUN	19
10	MAINTENANCE	CONTINUE	

STONE OUTLET STRUCTURE
(not to scale)

Flow
6" min.
Earth dike
Stone
Level crest
6" min.
12" min.
(as shown on plan) min.
Stone embedded 6" min.
Ground Line
PROFILE

Construction Specifications

1. The stone shall be crushed stone. Gravel may be used if crushed stone is not available. The stone shall meet MSHA Size No. 2 or AASHTO Designation M43 Size No. 2 or 24.
2. The crest of the stone dike shall be at least six inches lower than the lowest elevation of the top of the earth dike and shall be level.
3. The stone outlet structure shall be embedded into the soil a minimum of four inches.
4. The minimum length, in feet, of the crest of the stone outlet structure shall be equal to six times the number of acres of contributing drainage area.
5. The stone outlet structure shall be inspected after each rain, and the stone shall be repaired when the structure ceases to function as intended due to silt accumulation among the stone, washout, construction traffic damage, etc.

Standard Symbol SOS
* Drainage area less than 3 acres L =

U. S. DEPARTMENT OF AGRICULTURE
SOIL CONSERVATION SERVICE
College Park, Md.

STONE OUTLET STRUCTURE

Standard Drawing SOS-1

1" SURFACE COURSE BANK ST-1
1½" BINDER COURSE BANK BI 1-61
BITUMINOUS CONCRETE
DENSE GRADED STABILIZED AGGREGATE BASE COURSE
BITUMINOUS CONCRETE FOR PARKING AREAS

REVERSE CURB & GUTTER: SLOPE AT SAME RATE AS LINEAR-SLOPE ACROSS PAVING
LINE OF WATER FOR COMB. CURB & GUTTER WITH REVERSE SLOPE GUTTER (REV. C&G)
DRAINAGE FLOW
NOTE: PROVIDE MIN. 10' TRANSITION FROM STD. GUTTER TO REVERSE GUTTER. CONTRACTOR SHALL BE RESPONSIBLE FOR NOT TRAPPING WATER AT ANY POINT IN THE GUTTER
SECTION - CONCRETE COMBINATION CURB & GUTTER

8'-0" SEE SITE PLAN
1'-6"
1'-0"
FLOW LINE
FRONT VIEW
1'-0" 8"
7" CONCRETE APRON 4'-0"
½" EXP. JT.
SECTION
DEPRESSED CURB & GUTTER