

Interconnection - Preliminary Approval

Re: Frederick Co. Water & Sewer 4520 Metropolitan Ct. Frederick MD
Account number: GEN MD-6573-Battery Retrofit**

This transmittal serves as:

- A Notification that the Company has received your application for the above account and system
- B Notification that the Company has not found any deficiencies with your application
- C Notification that your application has been conditionally approved for interconnection

The subject interconnection application for the subject generating system has been conditionally approved for interconnection. Approval of your application is for operational purposes only. It is your responsibility to ensure compliance with any local, state or federal ordinances, statutes, regulations or other legal requirements. Any substantive changes to the proposed application must be approved by FirstEnergy prior to parallel operation.

The system inverter(s) should be configured to operate at unity (1.0) power factor.

Prior to interconnecting the generator with the company's electrical system, a completed Interconnection Agreement and Certificate of Completion, must be received and approved by FirstEnergy. Final approval to interconnect is contingent upon the Terms and Conditions of this Agreement, the return of a duly executed Certificate of Completion, verification of electrical inspection and successful witness test or EDC waiver thereof.

The requested information is complete and interconnection of the Customer-Generator Facility is approved contingent upon the Terms and Conditions of the Interconnection Agreement, the return of a duly executed Certificate of Completion, verification of electrical inspection and successful witness test or EDC waiver thereof.

The installation of the bidirectional meter, if applicable, will take place after the installation is complete & we have received the completed Interconnection Agreement, a completed Certificate of Completion, including evidence of having passed an electrical inspection for conformance with the provisions of the NEC and a completed Application for Service under the Net Energy Metering Rider where applicable.

The aforementioned forms are available on the Website listed below.

If you have any questions feel free to contact a member of our staff using the information provided below.

This Preliminary Approval is valid for (12) months from issuance. At that time, approval will be rescinded unless the applicant contacts the Company and demonstrates significant progress toward completion of the project, as determined by the Company.

Thank you.
Potomac Edison Company

10802 Bower Avenue
Williamsport, MD 21795-3016
Attn: Interconnection Coordinator

****CONDITIONAL APPROVAL IS CONTINGENT ON:**

-Approval of required protective relay settings and tests, and control system non-export mode settings by FirstEnergy Transmission Protection group

-Successful on-site witness test per approved commissioning procedure


Other Facility Information:

One Line Diagram attached: Yes No

Plot Plan attached: Yes No

Customer Signature

I hereby certify that all of the information provided in this application request form is true. I consent to permit the PSC and interconnecting utility to exchange information regarding the generating system to which this application applies.

Interconnection Customer Signature: 
Title: Director Date: 2/29/2019

An application fee is required before the application can be processed. Please verify that the appropriate fee is included with the application:

Application fee included
Amount \$890.00

EDC Acknowledgement

Receipt of the application fee is acknowledged and the interconnection request is complete.

EDC Signature:  Date: 2/27/20
Printed Name: Robert A. Kern Title: Distribution Tech II

GEN-MD- 6573 BATTERY RETROFIT
FREDERICK CO. WATER & SEWER
4520 METROPOLITAN CT.
FREDERICK MD

SEE ATTACHED CONDITIONAL APPROVAL + CONTINGENCIES